






VENDOR'S DRAWING REVIEW

☒ Approved - Mfg. may proceed.

☒ Approved - Submit final des. - Mfg. may proceed.

☐ Approved except as noted - Make changes and submit final des. - Mfg. may proceed as approved.

☐ Not approved - Correct and resubmit.


☐ Review not required - Mfg. may proceed.

Approval of this drawing does not relieve supplier from full compliance with contract or purchase order requirements.

RECEIVED Date 10/6/77

RECEIVED
OCT 6 1977
BECHTEL & CO.

FALCONBRIDGE NICKEL MINES LTD.
RECEIVED
OCT 15 1977
ENGINEERING DEPARTMENT



— RIB DETAIL —
TYPICAL
22-1/91
11018-M-89-001-2

— CONSTRUCTION NOTES: —

- TANK CONSTRUCTION TO CONFORM TO CGSB SPECIFICATION 41-GP-22
- RESIN: DERAKANE 470 WITH ULTRAVIOLET INHIBITOR
- APPROXIMATE WT: 2800 lbs
- SERVICE CONDITIONS: 10% SO₂ AND SULPHURIC ACID
- TEMP NOT TO EXCEED 220°F

— COLOUR NATURAL

LOWER NO 77-031

FALCONBRIDGE NICKEL MINES — LIMITED —		
ROASTER OFF-GAS SEAL POT		
DATE: SEPT 16/77	DRN: WLP	
SCALE: NOTED	CHD:	
SIZE	NUMBER	REV
C	PT-151	1